



CITY CORPORATION

Russellville Water and Sewer System

205 West 3rd Place PO Box 3186 Russellville, AR 72811-3186

Office (479) 968-2105
Fax (479) 968-3265

December 7, 2015

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for November 2015 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Solids, Total Suspended – Mon. Avg. Mass
2. Solids, Total Suspended – Mon. Avg. Con.
3. Solids, Total Suspended – 7-Day Avg. Con.
4. Total Residual Chlorine (TRC) – Inst. Max.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. TSS violations were caused by an extreme rain event during the month. All three parameter violations occurred during a day when the plant processed over 15 MGD with a peak flow of over 21 MGD. City Corporation continues to following collection system improvements as outlined in the CAP required by the CAO LIS No. 09-146.
2. The TRC violations were a direct result of operator error. Operators failed to effectively monitor the dechlorination process. The chemical feed system was not adjusted to ensure proper removal of chlorine from the effluent. All operators have been briefed and operation instructions given to ensure chemical feed system is operated correctly.

Should you have any questions or need other info please contact Larry Collins, Operations Manager at 479-968-2080 ext. 222.

Sincerely,

A handwritten signature in black ink, appearing to read "S Mallett", written in a cursive style.

Steve Mallett
General Manager

cc: Larry Collins
Randy Bradley
File