

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City Corporation NPDES Permit No.: AR0021768 Monitoring Period (Month/Year): November 2015

D No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions						
Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location			
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental. Impact	CR-Creek/Stream/River (specify)			
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch		
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet		
R-Rainfall	RG-Roots / Grease		HR-Hand Rodded	GR-Ground Surface		
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area		
			PN-Public Notification	CB-Contained in Building		

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
404 Jimmy Lile Road	8048	11/5/15	11/5/15	1,032,000	R	NEAH	EC	DI, CR-Whigg
404 Jimmy Lile Road	Treatment Plant	11/17/15	11/17/15	29,000	R	NEAH	EC	GR
E G St & N Greenwich	1725	11/17/15	11/17/15	2,550	R	NEAH	EC	PA
4th & Waco	1333	11/17/15	11/18/15	106,700	R	NEAH	EC	PA
1815 N El Paso	2043	11/17/15	11/18/15	213,000	R	NEAH	EC	DI, GR
John Trusty Lane	3191	11/17/15	11/18/15	296,450	R	NEAH	EC	DI, GR
407 N Arkansas	1825	11/17/15	11/18/15	151,000	R	NEAH	EC	CR-Prairie
3rd & Vancouver	1315	11/17/15	11/18/15	108,000	R	NEAH	EC	PA
N Glenwood & E O St	2050	11/17/15	11/18/15	378,950	R	NEAH	EC	DI, GR, CR-Prairie
1600 Blk N Glenwood	2048	11/17/15	11/18/15	352,250	R	NEAH	EC	DI, GR





Signature of Cognizant or Ranking Official **Date**

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City Corporation **NPDES Permit No.:** AR0021768 **Monitoring Period (Month/Year):** November 2015

D No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions						
Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location			
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental. Impact		CR-Creek/Stream/River (specify)		
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch		
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet		
R-Rainfall	RG-Roots / Grease		HR-Hand Rodded	GR-Ground Surface		
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area		
			PN-Public Notification	CB-Contained in Building		

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
1700 Blk S Glenwood	2817	11/17/15	11/18/15	28,075	R	NEAH	EC	GR
2807 N Arkansas	2024	11/17/15	11/18/15	278,200	R	NEAH	EC	DI, GR
3995 International Dr	Lift Station	11/20/15	11/20/15	5,000	R	NEAH	EC	GR
4th & Waco	1333	11/27/15	11/29/15	59,250	R	NEAH	EC	PA
3rd & Vancouver	1315	11/27/15	11/29/15	77,625	R	NEAH	EC	PA
4th & Arlington	1334	11/28/15	11/29/15	68,750	R	NEAH	EC	DI, GR
Hilltop & Marina Rd	3273	11/28/15	11/29/15	206,500	R	NEAH	EC	DI
1815 N El Paso	2043	11/28/15	11/29/15	194,400	R	NEAH	EC	DI, GR
220 Lakefront Dr	2035	11/28/15	11/29/15	97,050	R	NEAH	EC	CR-Prairie
407 N Arkansas	1825	11/28/15	11/29/15	134,400	R	NEAH	EC	CR-Prairie

Signature of Cognizant or Ranking Official **Date** 12-2-15

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City Corporation NPDES Permit No.: AR0021768 Monitoring Period (Month/Year): November 2015

D No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions						
Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location			
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental. Impact	CR-Creek/Stream/River (specify)			
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	DI-Ditch			
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	DR-Drop Inlet			
R-Rainfall	RG-Roots / Grease	EC-Environmental Cleanup	GR-Ground Surface			
RO-Roots	V-Vandalism	HC-Hydro Cleaned	PA-Paved Area			
		HR-Hand Rodded	CB-Contained in Building			
		EN-Referred to Engineering				
		PN-Public Notification				

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location
E G St & N Greenwich	1725	11/28/15	11/29/15	104,550	R	NEAH	EC	CR-Prairie
1416 S Boston Ave	5054	11/28/15	11/29/15	28,040	R	HEAH	EC	CR-Prairie
1300 N Glenwood	2816	11/28/15	11/29/15	64,250	R	NEAH	EC	CR-Prairie
N Glenwood & E O St	2050	11/28/15	11/29/15	322,500	R	NEAH	EC	CR-Prairie
1600 Blk N Glenwood	2048	11/28/15	11/29/15	354,750	R	NEAH	EC	CR-Prairie
1400 E F St	4058	11/28/15	11/28/15	450	G, R	NEAH	EC	DI, GR


 Signature of Cognizant or Ranking Official Date 12-2-15

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."