



CITY CORPORATION

Russellville Water and Sewer System

205 West 3rd Place PO Box 3186 Russellville, AR 72811-3186

Office (479) 968-2105
Fax (479) 968-3265

October 7, 2015

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for September, 2015, as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Nitrogen, Ammonia – Monthly Avg. Conc.
2. Nitrogen, Ammonia – 7 Day Avg.
3. BOD, Carbonaceous / 5 day – Monthly Avg. Mass
4. BOD, Carbonaceous / 5 day – Monthly Avg. Conc.
5. BOD, Carbonaceous / 5 day – 7 Day Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. The above permit violations were all cause by a slug event at the Treatment Plant the first week of September. Lab staff indicated a violations with the CBOD during the first week and by the second week the ammonia was above permit limits. This event was short in duration with plant within permit limits on September 10, 2015. Pretreatment staff contacted all permitted industries in efforts to determine source of toxic slug. As of today staff has been unable to locate source or identify the toxin. Pretreatment staff has started sampling within the collection system in efforts to determine location/source.

Should you have any questions or need other info please contact Larry Collins, Operations Manager at 479-968-2080 ext. 222.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Steve Mallett'.

Steve Mallett
General Manager

cc: Larry Collins
Randy Bradley
File