



P. 479-968-2105
F. 479-968-3265

"Award Winning Water"

October 9, 2017

Mr. Alan Anderson
Enforcement Analyst
Water Division/Enforcement Branch
Arkansas Department of Environmental Quality
5301 Northshore Dr.
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for September 2017 as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

1. Nitrogen, Ammonia Total (as N) – 7-day Avg.
2. Coliform, Fecal – 7-day Geo Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

1. These violations occurred on August 30, 2017 and were caused by the slug load as reported with the August DMR. As of today, the plant has fully recovered and meeting all permit parameters.

Should you have any questions or need other info please contact Larry Collins, Chief Operations Officer at 479-968-2080 ext. 222.

Sincerely,


Steve Mallett
Chief Executive Officer

cc: Larry Collins
Randy Bradley
File

205 W. 3rd Place
PO Box 3186
Russellville, AR 72811
citycorporation.com