



# CITY CORPORATION

Russellville Water and Sewer System

205 West 3rd Place PO Box 3186 Russellville, AR 72811-3186

Office (479) 968-2105

Fax (479) 968-3265

March 10, 2016

Mr. Alan Anderson  
Enforcement Analyst  
Water Division/Enforcement Branch  
Arkansas Department of Environmental Quality  
5301 Northshore Dr.  
North Little Rock, Arkansas 72118

RE: NPDES Permit No. AR0021768, AFIN 58-00105

Dear Mr. Anderson:

This letter shall serve as the noncompliance report (NCR) for February, 2016, as required by NPDES permit AR0021768.

During this reporting period City Corporation experienced permit violations for the following parameters:

Ammonia Nitrogen (NH<sub>3</sub>-N) – Monthly Avg. Mass, lbs/day  
Ammonia Nitrogen (NH<sub>3</sub>-N) – Monthly Avg. Concentration  
Ammonia Nitrogen (NH<sub>3</sub>-N) – 7-day Avg.

The above violations were caused by the following events at the Pollution Control Works during this reporting period.

The ammonia violation is a continuation from an even that occurred in January. The activated sludge that was introduced into our system showed some improvement in the ability of our system to reduce the ammonia but has not fully recovered as of this report. Staff continues in efforts to locate any source of toxins that may be interfering with the nitrification process.

Should you have any questions or need other info please contact Larry Collins, Operations Manager at 479-968-2080 ext. 222.

Sincerely,

A handwritten signature in black ink, appearing to read 'S. Mallett'.

Steve Mallett  
General Manager

cc: Larry Collins  
Randy Bradley  
File