



CITY CORPORATION

Russellville Water and Sewer System

205 West 3rd Place PO Box 3186 Russellville, AR 72811-3186

Phone (479) 968-2105
FAX (479) 968-3265

February 11, 2014

Alan Anderson
NPDES Enforcement Section
Arkansas Department of Environmental Quality
5301-North Shore Dr
North Little Rock, Arkansas 72118

RE: Storm water Blending February 4, 2014 thru February 4, 2014
Russellville City Corporation Pollution Control Works
NPDES Permit No. AR0021768 AFIN 58-0015

Dear Mr. Anderson:

In an attempt to save the City Corporation Pollution Control Works from becoming hydraulically overloaded, we would provide the following data for the storm water blending event that occurred at the Pollution Control Works, Tuesday February 4, 2014 and ending Tuesday February 4, 2014. As was conveyed in the initial report this blending was due to excessive storm events experienced in the area.

We would offer the following results:

Gallons blended: 841,500 gallons estimated.

Tuesday, February 4, 2014

Total Suspended Solids	48.0 mg/l	CL2	0.00 mg/l
Dissolved Oxygen	9.2 mg/l	pH	6.95
Ammonia	8.27 mg/l	BOD	15.5 mg/l
Fecals	8,700/100ml		


Sincerely,

A handwritten signature in black ink, appearing to read 'Steve Mallett'.

Steve Mallett
General Manager

cc: Randy Bradley
File

CERTIFIED MAIL™




7012 3460 0002 4998 9817

PLACE
811-3186



UNITED STATES
POSTAL SERVICE

1000



72118

U.S. POSTAGE
PAID
RUSSELLVILLE, AR
72801
FEB 12, 14
AMOUNT

\$0.24

00824761-04

neopost
02/12/2014

US POSTAGE

\$06.25⁰



ZIP 72801
041L11235277

ADEQ
5301 North Shore Drive
North Little Rock, AR 72118

Attn: Alan Anderson

72118532801

