



CITY CORPORATION

Russellville Water and Sewer System

205 West 3rd Place PO Box 3186 Russellville, AR 72811-3186

Phone (479) 968-2105
FAX (479) 968-3265

May 16, 2014

Alan Anderson
NPDES Enforcement Section
Arkansas Department of Environmental Quality
5301 North Shore Dr
North Little Rock, Arkansas 72118

RE: Storm water Blending May 8, 2014 thru May 9, 2014
Russellville City Corporation Pollution Control Works
NPDES Permit No. AR0021768 AFIN 58-0015

Dear Mr. Anderson:

In an attempt to save the City Corporation Pollution Control Works from becoming hydraulically overloaded, we would provide the following data for the storm water blending event that occurred at the Pollution Control Works, Thursday May 8, 2014 and ending Friday May 9, 2014. As was conveyed in the initial report this blending was due to excessive storm events experienced in the area.

We would offer the following results:

Gallons blended: 2,150,500 gallons estimated.

Thursday May 8, 2014

Total Suspended Solids	20.0 mg/l	CL2	0.03 mg/l
Dissolved Oxygen	7.3 mg/l	pH	7.00
Ammonia	3.23 mg/l	BOD	11.7 mg/l
Fecals	2,450/100ml		

Friday, May 9, 2014

Total Suspended Solids	26.7 mg/l	CL2	0.00 mg/l
Dissolved Oxygen	7.7 mg/l	pH	6.76
Ammonia	4.12 mg/l	BOD	11.7 mg/l
Fecals	930/100ml		

Sincerely,

Steve Mallett
General Manager

cc: Randy Bradley
File



P.O. BOX 3186 • 205 WEST THIRD PLACE
RUSSELLVILLE, ARKANSAS 72811-3186

CERTIFIED MAIL™



7012 3460 0000 3858 1499

neopost[®]

05/19/2014

US POSTAGE

\$06.48⁰



ZIP 72801
041L11235277

ADEQ
5301 North Shore Drive
North Little Rock, AR 72118

Attn: Alan Anderson

72118531799

