



City of Nashville

Mayor Larry Dunaway
426 N Main St
Nashville, AR 71852



March 21, 2023

ADEQ
Attn: Water Quality Enforcement
Division of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re: Unpermitted Discharge Nashville WWTP
Permit #0021776 AFIN: 310036


To whom it may concern,

The unpermitted discharge reported on Monday March 13, 2023 stopped on Tuesday March 14, 2023. The overflow was due to an excessive rainfall event of 2 inches that fell on March 11th and 12th. The overflow is estimated to be 28 gpm or .04032 million gallons over a period of 24 hours. There was no evidence of adverse health or environmental impact. To prevent this from happening again the Nashville WWTP will try to keep at least 24 or more inches of free board on the EQ basin.

If you have any questions or concerns, please call my office at 870-845-7400.

Sincerely,


Larry Dunaway
Mayor
City of Nashville

870-845-7400 

npw@nashar.org 

Nashar.org 

870-845-7409 



City of Nashville

Mayor's Office

426 N Main St

Nashville, AR 71852

SHREVEPORT LA 710

22 MAR 2023PM 1 L

stamps
.com

\$0.60 0

**US POSTAGE
FIRST-CLASS**
062S0014950499
FROM 71852

B73369 23



stamps
.com

ADEQ

Attn: Water Quality Enforcement

Division of Environmental Quality

5301 Northshore Drive

North Little Rock, AR 72118-5317

72118-531799

