

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021831 Discharge Number: Y - 001-Annual

Facility: City of Monticello - East Plant

Address: 10000 Florence Road

City: Monticello State: AR Zip: 71639

Contact: Mayor Paige Chase Phone: 870-367-4400

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
March, 2022	pH		9.3 units Max	9.0 units Max limit

We feel this problem was due to:

miscalibration of the pH meter

We plan on correcting the problem in this manner:

The WW II operators now know how to calibrate the pH meter

Time estimated that it will take to correct the problem/s:

The operators were shown how to recalibrate the pH meter on March 24th.

Sincerely,

Paige Chase

Authorized Signature

4-26-22

Date