

April 16, 2012

Honorable Frank Fogleman City of Marion P.O. Box 717 Marion, AR 72364

RE: NPDES Permit No. AR0021971, AFIN 18-00110

Dear Mayor Fogleman:

A review of the NPDES file for the City of Marion for January 1, 2012 thru February 29, 2012 revealed the following compliance issue:

The facility reported 10 violations of Part I, Section A. of NPDES Permit No.: AR0021971. The effluent violations reported on the Discharge Monitoring Reports are as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
01/31/12	001A	Nitrogen, ammonia total (as N) (MO AVG, lb/d)	116	90
01/31/12	001A	Nitrogen, ammonia total (as N) (MO AVG, mg/L)	8.3	6.7
02/29/12	001A	Solids, total suspended (MO AVG, lb/d)	434	267
02/29/12	001A	Solids, total suspended (MO AVG, mg/L)	24	20
02/29/12	001A	Solids, total suspended (7 DA AVG, mg/L)	62	30
02/29/12	001A	Nitrogen, ammonia total (as N) (MO AVG, lb/d)	261	90
02/29/12	001A	Nitrogen, ammonia total (as N) (MO AVG, mg/L)	15.3	6.7
02/29/12	001A	Nitrogen, ammonia total (as N) (7 DA AVG, mg/L)	15.5	12
02/29/12	001A	BOD, carbonaceous, 05 day, 20C (MO AVG, lb/d)	215	200
02/29/12	001A	BOD, carbonaceous, 05 day, 20C (7 DA AVG, mg/L)	42	22.5

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at <u>anderson@adeq.state.ar.us</u>.

Sincerely,

Alan Anderson Enforcement Analyst Water Division / Enforcement Branch