

May 6, 2013

Honorable Frank Fogleman City of Marion P.O. Box 717 Marion, AR 72364

RE: NPDES Permit No. AR0021971, AFIN 18-00110

Dear Mayor Fogleman:

A recent review of the above referenced permit has revealed the following permit effluent violations for the monitoring period ending March 2013:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
3/31/2013	001-A	Solids, total suspended (MO AVG, lb/d)	329	267
3/3/1/2013	001-A	Solids, total suspended (MO AVG, mg/L)	23.25	20
3/31/2013	001-A	Solids, total suspended (7 DA AVG, mg/L)	39	200
3/31/2013	001-A	Nitrogen, ammonia total (as N) (MO AVG, lb/d)	206	90
3/31/2013	001-A	Nitrogen, ammonia total (as N) (MO AVG, mg/L)	14.51	6.7
3/31/2013	001-A	Nitrogen, ammonia total (as N) (7 DA AVG, mg/L)	17.33	12

The Department expects the City of Marion to continue to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0636, or you may e-mail me at copenhaver@adeq.state.ar.us.

Sincerely,

Lindsay Copenhaver Enforcement Analyst

Water Division / Enforcement Branch