

# ADEQ

ARKANSAS  
Department of Environmental Quality

March 7, 2011

Honorable Frank Fogleman  
City of Marion  
P.O. Box 717  
Malvern, AR 72364

RE: NPDES Permit No. AR0021971, AFIN 18-00110

Dear Mayor Fogleman:

A review of the NPDES file for the City of Marion for the period of January 1, 2011 thru January 31, 2011 reveals the following compliance issue:

The facility reported 4 violations of Part I, Section A. of NPDES Permit No.: AR0021971. The effluent violations include:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
01/31/2011	001-A	Nitrogen, ammonia total (as N) (MO AVG, lb/d)	259	90
01/31/2011	001-A	Nitrogen, ammonia total (as N) (MO AVG, mg/L)	21	6.7
01/31/2011	001-A	Nitrogen, ammonia total (as N) (7 DA AVG, mg/L)	32	12
01/31/2011	001-A	Chlorine, total residual (INST MAX, mg/L)	.92	.1

The Department assumes that the City of Marion continues to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at [anderson@adeq.state.ar.us](mailto:anderson@adeq.state.ar.us).

Sincerely,



Alan Anderson  
Enforcement Analyst  
Water Division / Enforcement Branch

