

ADEQ

ARKANSAS
Department of Environmental Quality

April 11, 2011

Honorable Frank Fogleman
City of Marion
P.O. Box 814
Marion, AR 72364

RE: NPDES Permit No. AR0021971, AFIN 18-00110

Dear Mayor Fogleman:

A review of the NPDES file for the City of Marion for the period of February 1, 2011 thru February 28, 2011 reveals the following compliance issues:

The facility reported 4 violation of Part I, Section A. of NPDES Permit No.: AR0021971. The effluent violation reported on the DMR is as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
02/28/11	001A	Nitrogen, ammonia total (as N) (MO AVG, lb/d)	342	90
02/28/11	001A	Nitrogen, ammonia total (as N) (MO AVG, mg/L)	28.3	6.7
02/28/11	001A	Nitrogen, ammonia total (as N) (7 DA AVG, mg/L)	31	12
02/28/11	001A	Chlorine, total residual (INST MAX, mg/L)	.98	.1

The Department expects the City of Marion to continue to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Also, the progress report toward compliance with the Ammonia Nitrogen limits contained in the Permit was due on 02/01/2011, but was not received at the Department until 03/28/2011.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at anderson@adeq.state.ar.us.

Sincerely,



Alan Anderson
Enforcement Analyst
Water Division / Enforcement Branch

