

ADEQ

ARKANSAS
Department of Environmental Quality

July 8, 2011

Honorable Frank Fogleman
City of Marion
P.O. Box 717
Marion, AR 72364

RE: NPDES Permit No. AR0021971, AFIN 18-00110

Dear Mayor Fogleman:

A review of the NPDES file for the City of Marion for April 1, 2011 thru April 30, 2011 revealed the following compliance issue:

The facility reported 3 violations of Part I, Section A. of NPDES Permit No.: AR0021971. The effluent violations reported on the DMR are as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
04/30/11	001A	Nitrogen, ammonia total (as N) (MO AVG, lb/d)	288	90
04/30/11	001A	Nitrogen, ammonia total (as N) (MO AVG, mg/L)	16.6	6.7
04/30/11	001A	Nitrogen, ammonia total (as N) (7 DA AVG, mg/L)	17.8	12

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at anderson@adeq.state.ar.us.

Sincerely,



Alan Anderson
Enforcement Analyst
Water Division / Enforcement Branch

