



November 27, 2018

Honorable Frank Fogleman, Mayor
City of Marion
P.O. Box 717
Marion, AR 72364

email: mayormarionar@aol.com

**RE: Permit Number: AR0021971, AFIN: 47-00991
Effluent Violation Warning Letter**

Dear Mayor Fogleman:

A review of the Permit file for the above mentioned facility for the period of April 1, 2018 through October 31, 2018 reveals the following compliance issues:

The facility has reported **6 violations** of Part I, Section A of Permit No. AR0021971:

Date	Disch#	Parameter Description	Reported Value	Limit Value	Vio%
08/31/2018	002-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	44.13	30	47%
08/31/2018	002-A	BOD, 5-day, 20 deg. C (7 DA AVG, mg/L)	98	45	118%
08/31/2018	002-A	Coliform, fecal general (30DA GEO, #/100mL)	339.53	200	70%
08/31/2018	002-A	Coliform, fecal general (7 DA GEO, #/100mL)	818	400	105%
10/31/2018	002-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	43.67	30	46%
10/31/2018	002-A	BOD, 5-day, 20 deg. C (7 DA AVG, mg/L)	61	45	36%

Non-compliance reports were received by the Department. Any violation of your Permit is subject to further enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0639, or you may e-mail me at bailey.taylor@adeq.state.ar.us.

Sincerely,

Bailey Taylor
Enforcement Coordinator
Office of Water Quality

cc: Jim Shempert, Manager, City of Marion (jshempert.waterdept@yahoo.com)