

February 17, 2022

Honorable Frank Fogleman Mayor, City of Marion P.O. Box 717 Marion, AR 72364

RE: Permit Number: AR0021971, AFIN: 18-00110

Effluent Violation Warning Letter

Dear Mayor Fogleman:

A review of the Permit file for the above mentioned facility for the period of October 1, 2021 through December 31, 2021 reveals the following compliance issues:

email: jkelley502mbd@yahoo.com

The facility has reported <u>7 effluent violations</u> of Part I, Section A of Permit No. AR0021971:

DMR End Date	Disch- Desig	Parameter Desc	Reported DMR Value	Limit Value
09/30/2021	002-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	34.2	30
10/31/2021	002-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	70.75	30
10/31/2021	002-A	BOD, 5-day, 20 deg. C (7 DA AVG, mg/L)	95.5	45
11/30/2021	002-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	52.56	30
11/30/2021	002-A	BOD, 5-day, 20 deg. C (7 DA AVG, mg/L)	73.5	45
12/31/2021	002-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	65.76	30
12/31/2021	002-A	BOD, 5-day, 20 deg. C (7 DA AVG, mg/L)	75.5	45

Any violation of your Permit is subject to further enforcement action by this Division, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0840, or you may e-mail me at christina.mccutcheon@adeq.state.ar.us.

Sincerely,

Christina McCutcheon

Enforcement Analyst, DEQ, OWQ

5301 Northshore Drive, North Little Rock, AR 72118