

# ADEQ

ARKANSAS  
Department of Environmental Quality

June 1, 2011

Honorable Frank Fogleman  
City of Marion  
P.O. Box 717  
Marion, AR 72364

RE: NPDES Permit No. AR0021971, AFIN 18-00110

Dear Mayor Fogleman:

A review of the NPDES file for the City of Marion for March 1, 2011 thru March 31, 2100 revealed that the following Discharge Monitoring Report (DMR) has not been received by the Department:

- DMR End Date 03/31/11, Discharge TX1Q.

Please submit the delinquent DMR and any applicable non-compliance report to the Department by June 7, 2011. The DMR must include an original signature and date by the Principal Executive Officer or Authorized Agent. Photocopied signatures cannot be accepted.

Furthermore, the facility reported 3 violations of Part I, Section A. of NPDES Permit No.: AR0021971. The effluent violations reported on the DMR are as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
03/31/11	001A	Nitrogen, ammonia total (as N) (MO AVG, lb/d)	288	90
03/31/11	001A	Nitrogen, ammonia total (as N) (MO AVG, mg/L)	28.8	6.7
03/31/11	001A	Nitrogen, ammonia total (as N) (7 DA AVG, mg/L)	29.7	12

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at [anderson@adeq.state.ar.us](mailto:anderson@adeq.state.ar.us).

Sincerely,



Alan Anderson  
Enforcement Analyst  
Water Division / Enforcement Branch

