



**ARKANSAS**  
ENERGY & ENVIRONMENT

Facility: Marion AR0021971

# MEETING ATTENDANCE

Date: October 5, 2021 at 10:30am via Zoom

Name	Organization	Job Title	E-Mail Address	Telephone Number
Richard Healey	DEQ	Enforcement Branch Manager	<a href="mailto:healeyr@adeq.state.ar.us">healeyr@adeq.state.ar.us</a>	501-682-0640
Sarah Pierce	DEQ	Enforcement Analyst	<a href="mailto:Sarah.pierce@adeq.state.ar.us">Sarah.pierce@adeq.state.ar.us</a>	501-682-0664
Danielle Harbin	DEQ	Enforcement Coordinator	<a href="mailto:danielle.harbin@adeq.state.ar.us">danielle.harbin@adeq.state.ar.us</a>	501-682-0056
Frank Fogleman	City of Marion	Mayor	<a href="mailto:mayormarionar@aol.com">mayormarionar@aol.com</a>	
Jerry Kelly	City of Marion	Operator	<a href="mailto:jkelly502mbd@yahoo.com">jkelly502mbd@yahoo.com</a>	
Jerome Alford	Bond Engineering	Engineer	<a href="mailto:bondengineering@hotmail.com">bondengineering@hotmail.com</a>	
Danny Bowman				

**REMARKS:**

# AGENDA

## DEQ Zoom meeting with City of Marion

Tuesday, October 5, 2021 at  
10:30am

1. Introductions
2. Discussed update on plans for plant
  - a. Original plans were to have 4 aerators, but have only had 2.
  - b. Two aerators have been ordered and should be installed in 30 days.
  - c. Plans to spread sludge to help level all the ponds.
  - d. Working on a better sample schedule.
3. Discussed finances
  - a. Stated they were able to handle updates
4. Discussed CAO
  - a. If in compliance a CAO will not be needed; however, if cannot certify compliance within 90 days, a CAO will be drafted
5. Follow-up
  - a. Coordinate with lab to adjust sampling.
  - b. In 90 days (January 3, 2022)
    - Submit to DEQ certification, from an engineer, that the 2 new aerators have been installed and the facility is in compliance
    - If not in compliance, submit a Revised CAP
  - c. A complete permit renewal is due by April 3, 2022, coordinate with your permit engineer Kai Imamura (501-682-0045 or by email at [Kai.Imamura@adeq.state.ar.us](mailto:Kai.Imamura@adeq.state.ar.us)) to update permit with correct facility setup.