

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0021971 AF18-00110 Discharge Number: 002

Facility: City of Marion

Address: 5054 Hardin Road

City: Marion State: AR Zip: 72364

Contact: Jerry Kelley Phone: 901-326-2421

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
4-27-23	BOD monthly limit	36		30

We feel this problem was due to:

I believe Sludge build up and lack of aeration is the main reason for the BOD issues.
WE have been given a notice and Bong engineering is doing a CAP for us and should
be in touch with ADEQ very soon. We are viewing a few different thing to see the most
cost efficient way to fix it.

We plan on correcting the problem in this manner:

The state should recieve the CAP soon and details will be included.

Time estimated that it will take to correct problem:

I havent seen anything from the engineers yet but I am pushing them to get the
information.

Sincerely,

Jerry Kelley

05-23-23

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)