

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0021971 Discharge Number: 002  
Facility: City of Marion  
Address: 5054 Hardin Road.  
City: Marion State: AR Zip: 72364  
Contact: Jerry Kelley Phone: 901-326-2421

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5-31-21	Bod monthly average		47.63	30
5-31-21	Bod 7day average		51.0	45

We feel this problem was due to:

I feel the aeration is our main problem. One of the aeration failed. Taking bids for 2 20hp aerators.


We plan on correcting the problem in this manner:

We are fixing the broken one. Fixing the old one + the new one should fix the problem. Oxygen.

Time estimated that it will take to correct problem:

Est time for the equipment November 2021

Sincerely,

  
Submitted By:

8-27-21  
Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality – Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: Permit No: AR0021971, AFIN<sup>18-00110</sup> Discharge Number: 002  
 Facility: City of Marion  
 Address: 5054 Hardin Road  
 City: Marion State: AR Zip: 72364  
 Contact: Jerry Kelley Phone: 901-326-2421

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
4-30-21	5 Day BOD <sub>5</sub> Max		49.56	30
4-30-21	5 Day BOD <sub>5</sub> Day		81.5	45

We feel this problem was due to:

I feel aeration is our main problem. One of our aerators has failed. We are taking bids for 2 20hp aerators. We should have prices back by 15th Sep. 21.

We plan on correcting the problem in this manner:

Meanwhile we are fixing the broken aerator. This with the 2 new ones ~~should~~ should fix our oxygen problem.

Time estimated that it will take to correct problem:

Depending on the time it takes us to get the new equipment. We are ~~hoping~~ hoping by November.

Sincerely,

Jerry W. Kelley

8-27-21

Submitted By

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)