

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality – Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: Permit No: AR0021971 Discharge Number: TX2-RT  
 Facility: City of Marion  
 Address: 5054 Hardin Rd  
 City: Marion State: AR Zip: 72364  
 Contact: Scott Marshall Phone: 870-739-6655

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Week 8/13-8/19	No samples taken			
Week 8/20-8/26	No samples taken			

**We feel this problem was due to:**

Ligthning struck the power grid in the area during a storm on 8/10/23 causing an overload on the control panel for the effluent pumps. We could not take samples during this time due to no outflow.

**We plan on correcting the problem in this manner:**

We contacted a contractor to replace overloaded parts.

**Time estimated that it will take to correct problem:**

A temporary fix was installed during the week of 8/27, but a permanent fix will not happen for several months due to a shortage of replacement parts.

Sincerely,

*Tracy Brook* 9/25/23  
 Submitted By: \_\_\_\_\_ Date: \_\_\_\_\_

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)