

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 Office of Water Quality – Enforcement Branch
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: Permit No: AR0021971 Discharge Number: 002 -A
 Facility: City of Marion
 Address: 310 Judge Smith
 City: City of Marion State: AR Zip: 72364
 Contact: Jerry W. Kelley Phone: 901-326-2421

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>1-17-23</u>	<u>E BOD</u>			
	<u>Monthly average</u>	<u>32.75</u>		<u>30</u>

We feel this problem was due to:

We feel the Monthly Average was out due to a aerator being down. The other was due to a mistake at the lab and only one of the twice weekly samples was tested.

We plan on correcting the problem in this manner:

We are having the aerator fixed as soon as we can ~~get~~ get on the levee. The Ground is wet and soft.

Time estimated that it will take to correct problem:

One month should be enough time to make repairs.

Sincerely,

Jerry W. Kelley
 Submitted By:

2-21-23
 Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)