

Marion Water Department

MAYOR
FRANK A FOGLEMAN

WATER UTILITIES MANAGER
JIM SHERPERT

31 MILITARY ROAD
P.O. BOX 814
MARION, ARKANSAS 72364
PHONE: 870-739-3073
FAX: 870-739-5415

WATER & SEWER COMMITTEE

JIM SPENCE, CHAIRMAN
KELLY O'NEAL
CLIFF WOOD

November 15, 2018

Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Ar. 72118-5317

Attn: Baily Taylor- Enforcement Analyst

Re: City of Marion
NPDES Permit No. AR0021971
AFIN- 00110

Dear Baily,

The City of Marion failed to meet permit requirements for BOD in October. We attribute this failure to pond turnover due to weather change. After viewing our first week's sample results of November our numbers appear to be back in compliance of our permitted limits.

Sincerely,



Jim Shempert
Marion Water and Wastewater Manager