

Kristen Graham (adpce.ad)

From: Scott Marshall <s.marshall.mws@gmail.com>
Sent: Wednesday, August 16, 2023 9:58 AM
To: Kristen Graham (adpce.ad)
Subject: Sewer Plant Issues

As per our conversation, I am sending an email about issues with sampling per our Permit at the sewer plant for the City of Marion, AR.

On Thursday August 10th, we had a storm coming through the area. Lightning struck the area causing our control panel for the effluent pumps to quit working. We had an electrician come out to find the problem and get it fixed. As of today (Aug 16, 2023), the system is down until the electrician finds replacement parts to rebuild our control panel.

During this time we will be out of compliance on sampling per our permit requirements.

Scott Marshall
Utilities Director
City of Marion, AR