


Sanitary Sewer Overflow Monthly Report

Facility Name: Marion, City of Permit Number: AR0021971 Reporting Period(Month/Year): AUGUST 2013

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact		CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure/Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location

Signature of Cognizant or Ranking Official: 

Date: 9/18/13

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Marion Water Department

MAYOR
FRANK A FOGLEMAN

WATER UTILITIES MANAGER
JIM SHERPERT

31 MILITARY ROAD
P.O. BOX 814
MARION, ARKANSAS 72364
PHONE: 870-739-3073
FAX: 870-739-5415

WATER & SEWER COMMITTEE

JIM SPENCE, CHAIRMAN
KELLY O'NEAL
CLIFF WOOD


September 18, 2013

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive

August 2013 Non-Compliance Letter:


We have recently lowered our wastewater ponds in anticipation of doing some levee work. As a result of this we have exceeded our permit limits on N and by 1 mg/l on TSS. We also had a malfunction with our chlorinator for one sample day resulting in high sample readings. We have made repairs and adjusted our chlorinator.

Jim Shempert



Water Utilities Manager

31 MILITARY RD
MARION, AR
72364



ADEC
NPDES ENFORCEMENT SECTION
5301 NORTHSORE DRIVE
NORTH LITTLE ROCK, AR.

72118-5317

