

# Marion Water Department

MAYOR  
FRANK A FOGLEMAN

31 MILITARY ROAD  
P.O. BOX 814  
MARION, ARKANSAS 72364  
PHONE: 870-739-3073  
FAX: 870-739-5415

WATER & SEWER COMMITTEE

WATER UTILITIES MANAGER  
JIM SHERPERT

JIM SPENCE, CHAIRMAN  
KELLY O'NEAL  
CLIFF WOOD

August 19, 2014

Arkansas Department of Environmental Quality  
5301 North Shore Drive  
North Little Rock, Arkansas 72118-5317

Re: July 2014 Non-Compliance Letter


Marion has finally received a break in rainfall and we are now lowering are ponds for upcoming construction of our wastewater plant and pipeline to the Mississippi River. We think a large algae bloom and the lower water levels have caused our current parameter excursions of BOD and TSS. We also think the excess algae effected our Chlorine Residual. We now have a handle on our dosage dealing with the algae problem. We will continue to monitor our weekly samples.

Jim Shempert

  
Water Utilities Manager



31 MILITARY RD.  
MARION, AR.  
72364



ADEQ  
5301 NORTH SHORE DRIVE  
NORTH LITTLE ROCK, AR.

72118-5817