

Marion Water Department

MAYOR
FRANK A FOGLEMAN

WATER UTILITIES MANAGER
JIM SHERPERT

31 MILITARY ROAD
P.O. BOX 814
MARION, ARKANSAS 72364
PHONE: 870-739-3073
FAX: 870-739-5415

WATER & SEWER COMMITTEE

JIM SPENCE, CHAIRMAN
KELLY O'NEAL
CLIFF WOOD

April 15, 2014


Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive

March 2014

Non-Compliance Letter:


We have been pumping with a relift pump for the last three months from our 3rd cell of our lagoons into our Rock Beds to help lower our pond levels. This pumping we think is causing us to exceed our permit limits on TSS and AMMONIA NITROGEN and this month BOD. We hope to have our pond levels back to normal soon allowing us to terminate this extra pumping.

Jim Shempert



Water Utilities Manager

31 MILITARY RD
MARION AR,
72364



UNITED STATES POSTAGE
PITNEY BOWES

02 1P \$ 001.40⁰
0000818171 APR 15 2014
MAILED FROM ZIP CODE 72364

ADEQ
NPDES ENFORCEMENT SECTION
5301 NORTHSORE DRIVE
NORTH LITTLE ROCK, ARKANSAS
72118-5317