

Marion Water Department

MAYOR
FRANK A FOGLEMAN

WATER UTILITIES MANAGER
JIM SHERPERT

31 MILITARY ROAD
P.O. BOX 814
MARION, ARKANSAS 72364
PHONE: 870-739-3073
FAX: 870-739-5415

WATER & SEWER COMMITTEE

JIM SPENCE, CHAIRMAN
KELLY O'NEAL
CLIFF WOOD

June 18, 2013

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive


May 2013 Non-Compliance Letter:

We continue to struggle with Ammonia Nitrogen and Total Suspended Solids, although our numbers are closer to our parameter limits. Again we think the excessive amount of rainfall was a contributing factor. We also had a chlorinator malfunction on May 21 causing high numbers for 7 day average. We hope to be back in compliance next month with more normal rainfall totals.

Jim Shempert

Water Utilities Manager

31 MILITARY ROAD
MARION, AR.
72364



ADEQ
NPDES ENFORCEMENT SECTION
5301 NORTH SHORE DRIVE
LITTLE ROCK, ARKANSAS

72118-5317