

Marion Water Department

MAYOR
FRANK A. FOGLEMAN

WATER UTILITIES MANAGER
JIM SHERPERT

31 MILITARY ROAD
P.O. BOX 814
MARION, ARKANSAS 72364
PHONE: 870-739-3073
FAX: 870-739-5415

WATER & SEWER COMMITTEE

JIM SPENCE, CHAIRMAN
KELLY O'NEAL
CLIFF WOOD

September 9, 2014

Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118-5317

Re; August 2014 Non-Compliance Letter


Marion has lowered its wastewater levels for our ongoing wastewater pipeline construction project. Lowering these levels has effected our ability to meet permit on TSS, BOD and we habitually have problems in the summer with Ammonia Nitrogen. We also experienced chlorinator problems the last week of August causing our Fecal excursions.

Jim Shempert



Water Utilities Manager

31 MILITARY RD.
MARION, AR.
72364



ADEQ
5301 NORTHSORE DRIVE
NORTH LITTLE ROCK, ARKANSAS
72118-5317

