

# Marion Water Department

MAYOR  
FRANK A FOGLEMAN  
  
WATER UTILITIES MANAGER  
JIM SHERPERT

31 MILITARY ROAD  
P.O. BOX 814  
MARION, ARKANSAS 72364  
PHONE: 870-739-3073  
FAX: 870-739-5415

WATER & SEWER COMMITTEE  
  
JIM SPENCE, CHAIRMAN  
KELLY O'NEAL  
CLIFF WOOD

October 17, 2013

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive

September 2013 Non-Compliance Letter:

We think due to the lowering of our wastewater ponds for repair work on the levees, we caused the exceedance of our permit limits on TSS and Ammonia Nitrogen. I have checked our lab reports for the first two weeks of October and we are back within our permit.


Jim Shempert



Water Utilities Manager



31 MILITARY RD  
MARION, AR.  
72364



ADEQ  
NPDES ENFORCEMENT SECTION  
5301 NORTHSORE DRIVE  
North Little Rock, AR. 72118

