

Marion Water Department

MAYOR
FRANK A FOGLEMAN

WATER UTILITIES MANAGER
JIM SHERPERT

31 MILITARY ROAD
P.O. BOX 814
MARION, ARKANSAS 72364
PHONE: 870-739-3073
FAX: 870-739-5415

WATER & SEWER COMMITTEE

JIM SPENCE, CHAIRMAN
KELLY O'NEAL
CLIFF WOOD

October 13, 2014

Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118-5317

Re: September 2014 Non-Compliance


Marion continues to struggle to meet permit on TSS, Ammonia Nitrogen and this month Fecal Coliform. As reported last month we have lowered our lagoon levels in anticipation of our ongoing pipeline construction project. The lowering of our lagoons has made it difficult for us to maintain the correct TRC with this algae discharge. We will continue to diligently monitor Fecal Coliform numbers and make corrections as needed.

Jim Shempert



Water Utilities Manager

31 MILITARY RD.
MARION, AR.
72364



ADEQ
5301 NORTHSORE DRIVE
NORTH LITTLE ROCK, ARKANSAS
72118-5317

