

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022004 Discharge Number: 001
Facility: City of Huntsville Wastewater Facility
Address: PO Box 430
City: Huntsville, AR State: AR Zip: 72740
Contact: Larry Garrett Phone: 479-738-6929

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>08/14/2019</u>	<u>D.O.</u>		<u>6.49</u>	<u>6.60</u>

We feel this problem was due to:

Let oxygen drop too low in plant
Corrected by raising DO inside plant it came backup


We plan on correcting the problem in this manner:

Looking to engineers for guidance to correct long term

Time estimated that it will take to correct problem:

2 months possibly for engineers to look and in place

Sincerely,


Submitted By:

9/6/2019
Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0022004 Discharge Number: 001
Facility: City of Huntsville Wastewater Facility
Address: PO Box 430
City: Huntsville State: AR Zip: 72740
Contact: Larry D. Garrett Phone: 479-738-6929

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
08-01-2019	Fecal Day Average		2420 mg/L	2000 mg/L

We feel this problem was due to:
plant upset from Industry causing partial die-off

We plan on correcting the problem in this manner:
added bacteria AND ~~less~~ decreased flow from Industry AND plant recovered quickly

Time estimated that it will take to correct problem:
Already corrected the few days after

Sincerely,
Larry D. Garrett 08/01/2019
Submitted By: _____ Date _____

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)