

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
Office of Water Quality – Enforcement Branch  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: Permit No: AR0022004 Discharge Number: 001

Facility: Huntsville Wastewater Facility

Address: 30187 Highway 23 North

City: Huntsville State: AR Zip: 72740

Contact: Sean Davis Phone: 479-738-6929

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Feb 22 Monthly Avg	TSS		16 mg/L	15 mg/L

We feel this problem was due to:

Industrial loading from Butterball Turkey. An employee at Butterball reported that they had an equipment malfunction resulting in inadequate polymer addition to their wastewater system.

We plan on correcting the problem in this manner:

We have made adjustments to our treatment process to compensate for the additional loading while Butterball works to repair their equipment.

Time estimated that it will take to correct problem:

The plant adjustments have corrected the issue and we are pursuing chemical treatment options that would allow us to respond to similar issues more quickly in the future.

Sincerely,



03/17/2022

Submitted By:

Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)