

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
 Office of Water Quality – Enforcement Branch  
 5301 Northshore Drive  
 North Little Rock, AR 72118

RE: Permit No: AR0022004 Discharge Number: 001  
 Facility: Huntsville Wastewater Treatment Facility  
 Address: 30187 Madison Hwy 23  
 City: Huntsville State: AR Zip: 72740  
 Contact: \_\_\_\_\_ Phone: \_\_\_\_\_

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
6-1-18 thru 6-30-18	Nitrite + Nitrate		10.1 mg/l	10 mg/l
Monthly AVG				

We feel this problem was due to:

Industrial Over-loading to our facility

We plan on correcting the problem in this manner:

Discuss with Industry on a better Pretreatment program

Time estimated that it will take to correct problem:

Completed

Sincerely,

Larry D. Barrett

Submitted By:

6/13/2019  
 Date

Submitted electronically via NetDMR

**Certification Statement:** I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)