

MARK OWEN

REPORT OF NON-COMPLIANCE WITH EFFLUENT LIMITATIONS

PERMITEE: HUNTSVILLE WASTEWATER EFFLUENT

PERMIT: AR0022004 001A

REPORTING PERIOD: MAY 2012

REPORT DATE: JUNE 2012

PARAMETER(S)	NPDES MIN	NPDES AVG	NPDES MAX	RESULT REPORTED	DATE OF EXCURSION
NO3 + NO2 mg/L		10.00		11.5	*

* Excursion Dates Include: May 6th, 14th, 21st, 29th.

COMMENTS:

We experienced abnormal loading from our industry due to not receiving an equalized flow on weekends. We have contacted the industry which has installed a new flow meter to better control weekend flow. We are also implementing a more rigorous process control in our plant to control nitrate levels, and communicating with the industry on a daily basis.

PRINCIPAL EXECUTIVE OFFICER

TITLE

DATE


HUNTSVILLE WASTEWATER EFFLUENT



