

06/18/2014

Permit Violation

Permit # AR002204

On May 6, and May 21 we experienced low Dissolved Oxygen in our effluent. We are in touch with our engineers for a solution and trying to make sure our meter is correct.

The engineers are looking at a couple of options of dissipation blocks or a blower to create more oxygen.

Once a decision is made as to what we do I will inform you of these changes.

Thank you,

A handwritten signature in cursive script that reads "Larry D. Garrett". The signature is written in black ink and is positioned below the "Thank you," text.

Larry D. Garrett

Director

Huntsville Water Utilities

Sanitary Sewer Overflow (SSO) Monthly Report

Facility Name: City of Huntsville Wastewater Facility NPDES Permit No.: AR0022004 Monitoring Period (Month/Year): May 2014

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence Adverse Health/ Environmental Impact		CR-Creek/Stream/River (specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots / Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Discharge Location

Larry D. Barrett
Signature of Cognizant or Ranking Official


06-18/2014
Date

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."



Environmental Services Company, Inc.

1107 Century
Springdale, AR 72762
479-750-1170 Fax: 479-750-1172



ADEQ
WATER DIVISION, PERMITS
5301 NORTHSORE DR.
NORTH LITTLE ROCK AR 72118

72118\$5317 R015

