

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR002221 Discharge Number: A - 001-Monthly

Facility: West Helena Water Utilities

Address: SW/City Off Old Little Rock Rd

City: West Helena State: AR Zip: 72390

Contact: Jeff Patterson Phone: 870-816-5251

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
August, 2022	Fc		720 cfu/100mls	400 cfu/100mls 7 day geo limit

We feel this problem was due to:
No Flow & sample was pulled

We plan on correcting the problem in this manner:
Problem will be corrected when we start flowing

Time estimated that it will take to correct the problem/s:
1 week

Sincerely,

Authorized Signature

10-17-2022
Date