

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No:** AR002221      **Discharge Number:** A - 001-Monthly

---

**Facility:** West Helena Water Utilities

---

**Address:** SW/City Off Old Little Rock Rd

---

**City:** West Helena      **State:** AR      **Zip:** 72390

---

**Contact:** Jeff Patterson      **Phone:** 870-816-5251

---

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
August 3rd-31st	TSS	1,038.5 lb/d		900.7 lb/d Mo. Avg. limit
August 3rd-31st	CBOD	331.0 lb/d		250.2 lb/d Mo. Avg. limit

We feel this problem was due to:

---

---

---

We plan on correcting the problem in this manner:

---

---

---

Time estimated that it will take to correct the problem/s:

---

---

---

Sincerely,

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date