

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR002221 Discharge Number: A - 001-Monthly

Facility: West Helena Water Utilities

Address: SW/City Off Old Little Rock Rd

City: West Helena State: AR Zip: 72390

Contact: Jeff Patterson Phone: 870-816-5251


Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
December, 2020	TSS	294.2 lb/d		250.2 lb/d Mo. Avg. limit

We feel this problem was due to:
A low discharge level in the discharge pond.
We thought the levels would be ok due to extra rain
for the month of December 2020

We plan on correcting the problem in this manner:
When the ponds are at a low level, to shut flow off until
the level is back to normal level.
Then we can go back to discharging

Time estimated that it will take to correct the problem/s:
We believe that the problem is correct ponds are
discharging at normal level.

Sincerely,


Authorized Signature

1-25-2021
Date