

### NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No:** AR002221 **Discharge Number:** A - 001-Monthly

**Facility:** West Helena Water Utilities

**Address:** SW/City Off Old Little Rock Rd

**City:** West Helena **State:** AR **Zip:** 72390

**Contact:** Jeff Patterson **Phone:** 870-816-3251

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
July 26th, 2021	CBOD	349.4 lb/d		250.2 lb/d Mo. Avg. limit

We feel this problem was due to: *Discharge at pond was very low. Receiving pit very low. Decision made to stop flowing.*

We plan on correcting the problem in this manner: *No discharge and allow ponds to reach flowing levels.*

Time estimated that it will take to correct the problem/s: *RAINFALL. Timetable is uncertain due to NO*

Sincerely,  
  
Authorized Signature

*9-1-2021*  
Date