



TO:
FROM:

MR. Layne Pemberton

Jody Warren - West Helena Water

DATE: 8-7-17

FAX #: 1-501-682-0880

TOTAL PAGES INCLUDING COVER: 2

CONTACT:

COMMENT: Suplinentary Non-compliance Report



NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 6/01/2017 - 6/30/2017

FROM: City of West Helena
SW/City off Old Little Rock Rd
West Helena, AR 72390

DATE: 7/20/17

PERMIT #: AR0022021

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001:

2. NON-COMPLIANCE DESCRIPTION:

The Fecal Coliform exceeded permit limits for the month of June.

3. CAUSE FOR NON-COMPLIANCE:

Not sure, but got 6" rain in one day prior to sample being taken

4. DURATION OF NON-COMPLIANCE:

The non compliance description above took place between June 13th-27th, 2017.

5. CORRECTIVE ACTION BEING TAKEN:

NONE

SIGNATURE:

Jody P. Warner