

## NON-COMPLIANCE NOTIFICATION

**FROM:** West Helena Water Utilities  
SW/City Off Old Little Rock Rd.  
West Helena, AR 72390

**DATE:** 3/10/2015

**PERMIT #:** AR0022021

**TO:** NPDES Enforcement  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

---

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The pH exceeded the maximum value.

3. CAUSE FOR NON-COMPLIANCE:

Excessive Wind AND RAIN - Ponds Turned over

4. DURATION OF NON-COMPLIANCE:

The pH exceeded the maximum value on February 24th, 2015.

5. CORRECTIVE ACTION BEING TAKEN:

Self-CORRECTED


SIGNATURE: \_\_\_\_\_

*Ken Tratev*



**WEST HELENA WATER UTILITIES**

92 East Plaza Street  
West Helena, Arkansas 72390



Ar Dept of Environmental Quality  
Attn: NPDES Enforcement Br  
5301 Northshore Dr.  
N. Little Rock, AR 72118-5317

721185317 R015

