

ADEQ

ARKANSAS
Department of Environmental Quality

December 16, 2019

Heath Ward, Executive Director
Springdale Water and Sewer Com.
P.O. Box 769
Springdale, AR 72765

RE: NPDES Permit Number AR0022063, AFIN 72-00003
Permitted Effluent Limitation Violations

Dear Mr. Ward,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 2 violations of Part I, Section A of NPDES Permit No. AR0022063 during the review period. A detailed list of the violations has been included with this letter. The Department expects the Springdale Water and Sewer Com. to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

The Department recommends that the Springdale Water and Sewer Com. consult with a professional engineer for the purpose of developing a corrective action plan (CAP) designed to eliminate violations of the effluent limitations of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,



Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code
09/30/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	1.5	2.42	61%	E90
09/30/2018	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	2.3	6.68	190%	E90