

Springdale Water Utilities

Springdale, Arkansas

System Overflow Report for February 2023

This report submitted to Arkansas Department of Environmental Quality in compliance with Permit Number AR0022063 AFIN: 72-00003

Date	Time	Duration	Address	Est. Vol.	Cause of overflow	Remedial Action	Environmental Impact	Discharge Location
02/02/2023	12:15 pm-1:45 pm	1 hr. 30 min	101 Shoreline Drive Springdale, AR 72764	20 gal	Roots/Grease	Jet/Vac	None	Soaked into ground.
			Manhole # 109					
02/15/2023	10:30 am-11:15 am	45 mins	801 Fairway Circle Springdale, AR 72764	50 gal	Debris	Jet/Vac, Spread Lime on Affected Area	None	Into yard and storm drain.
02/21/2023	1:30 pm-2:30 pm	1 hr.	404 Geneva Street Springdale, AR 72762	50 gal	Roots/Grease	Jet/Vac, Spread Lime on Affected Area	None	Soaked into ground.
			Manhole #11004					

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that all qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature



Date: 03/09/2023