

Springdale Water Utilities

Springdale, Arkansas

System Overflow Report for September 2022

This report submitted to Arkansas Department of Environmental Quality in compliance with Permit Number AR0022063 AFIN: 72-00003

Date	Time	Duration	Address	Est. Vol.	Cause of overflow	Remedial Action	Environmental Impact	Discharge Location
09/11/2022	7:30 pm-9:00 pm	1 hr. 30 mins	6891 Garden Trail Ave Springdale, AR 72762	100 gal	Grease/Debris	Spread lime on affected area.	None	Soaked into ground & into storm drain
			Manhole #13663					
09/12/2022	1:25 pm-1:35 pm	10 mins	2910 Silent Grove Rd Springdale, AR 72762	25 gal	Equipment Failure	Spread lime on affected area, repaired equipment	None	Into ditch, soaked into ground
			Manhole #12053					
09/19/2022	12:35 pm-1:20 pm	45 mins	1044 Terry Ln Springdale, AR 72764	50 gal	Equipment Failure	Spread Lime on affected area, repaired equipment	None	Into yard, soaked into ground
			Step Tank					

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that all qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature



Date: 10/12/2022