

# Springdale Water Utilities

Springdale, Arkansas

## System Overflow Report for October 2023

**This report submitted to Arkansas Department of Environmental Quality in compliance with Permit Number AR0022063 AFIN: 72-00003**

Date	Time	Duration	Address	Est. Vol.	Cause of overflow	Remedial Action	Environmental Impact	Discharge Location
10/11/2023	10:00am-10:15am	15 mins.	2102 Westwood Ave. Springdale, AR 72762 Manhole # 2548	25 gal	Roots/Debris	Jet-Vac	None	Overflow into storm drain
10/24/2023	4:30pm-5:00pm	30 mins.	517 Riley Ln Springdale, AR 72764	50 gal	Line Failure/Break	Excavate and repair	None	Overflow into storm drain

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that all qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature  Date: 11/13/2023