

Anderson, Alan

From: Johnson, Miles
Sent: Wednesday, August 10, 2016 4:10 PM
To: Anderson, Alan
Subject: FW: Non Potable Reuse Water Discharge

Follow Up Flag: Follow up
Flag Status: Completed

From: Tim Hawkins [<mailto:thawkins@springdalewater.com>]
Sent: Wednesday, August 10, 2016 4:04 PM
To: SSOADEQ
Subject: Non Potable Reuse Water Discharge

To Whom It May Concern:

Springdale Water Utilities would like to report to ADEQ that one of our non-potable reuse water lines ruptured at our Wastewater Treatment Plant. Non-potable reuse water entered a storm drain which eventually discharged to Spring Creek. No untreated sewage was released.

The information for this incident is as follows:

Facility Name: SPRINGDALE, CITY OF
Permit Number: AR0022063

Date Incident Began: 8/9/2016
Time: 9:15 PM
Date Incident Ended: 8/9/2016
Time: 10:02 PM

Location Information: 2910 Silent Grove Rd, Springdale, AR 72762 - WWTP - 3" non-potable reuse water line ruptured at solids handling building - treated wastewater entered into storm drain.

Type of Overflow: Non potable reuse water line
Cause of Overflow: Line Failure/Break
Volume of Overflow: 10,575

Discharge Reached Receiving Water (Spring Creek)

No Evidence of Adverse Health/Environmental Impact

Action Taken: Repaired broken water line

Additional Comments: All discharge was treated wastewater. No environmental impact. No untreated sewage discharged.

Please let me know if you have any questions.

Thank you,

Tim Hawkins
Technical Services Director
Springdale Water Utilities
P.O. Box 769
Springdale, AR 72765
(479) 751-5751