

Springdale Water Utilities

Springdale, Arkansas

System Overflow Report for December 2013

This report submitted to Arkansas Department of Environmental Quality in compliance with Permit Number AR0022063 AFIN: 72-00003

Date	Time	Duration	Address	Est. Vol.	Cause of overflow	Remedial Action	Environmental Impact	Discharge Location
12/19/2013	11:00 am- 2:00 pm	3 hrs.	3184 North Thompson, Springdale, AR 72764	20 gal	Line Failure/break	Excavated broken clean out assembly and repaired. Removed solids and backfilled excavation.	None	Overflow soaked into ground.
12/23/2013	10:30 am- 10:50 am	20 mins.	1900 Sycamore Place, Springdale, AR	20 gal	Grease	Spread Lime on Affected Area	None	Overflow from manhole absorbed into ground.
12/26/2013	9:30 am- 10:45 am	1 hr, 15 mins.	2001 Turnbow Ave., Springdale, AR 72764	800 gal	Grease/Debris	Hydro Cleaned/Spread Lime on Affected Area	None	Manhole into storm sewer. Cleanout into yard -soaked into ground..


"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that all qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature Heath A. Wood

Date Jan 14, 2014

Springdale Water Utilities
P. O. Box 769
Springdale, AR 72765-0769

CERTIFIED MAIL™



7012 3050 0000 5906 6668

ADEQ
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118



1000



U.S. POSTAGE
PAID
GREENLAND, AR
72737
JAN 15, 14
AMOUNT

\$5.85

000 1160-



7211885317 R015

