

# Springdale Water Utilities

Springdale, Arkansas


## System Overflow Report for January 2016

This report submitted to Arkansas Department of Environmental Quality in compliance with Permit Number AR0022063 AFIN: 72-00003

Date	Time	Duration	Address	Est. Vol.	Cause of overflow	Remedial Action	Environmental Impact	Discharge Location
01/17/2016	4:00 pm- 4:30 pm	30 min.	504 Buford St. Springdale, AR	50 gal	Grease	Jet-Vac	None	Into storm drain.
01/22/2016	9:15 am- 9:45 am	30 min.	4101 Fairway Dr. Springdale, AR	100 gal	Grease/Debris	Jet-Vac, Spread Lime on affected areas.	None	Into yard.
01/23/2016	10:30 am- 11:00 am	30 min.	1716 Ross Ave. Springdale, AR	15 gal	Grease	Jet-Vac	None	Into yard.
01/23/2016	9:30 am- 10:00 am	30 min.	1808 Ross Ave. Springdale, AR	10 gal	Grease	Jet-Vac	None	Into street.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that all qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature



Date 02/16/2016

# Springdale Water Utilities

Springdale, Arkansas


## System Overflow Report for January 2016

This report submitted to Arkansas Department of Environmental Quality in compliance with Permit Number AR0022063 AFIN: 72-00003

Date	Time	Duration	Address	Est. Vol.	Cause of overflow	Remedial Action	Environmental Impact	Discharge Location
01/25/2016	12:30 pm- 1:10 pm	40 min.	4078 Jessica Lane Springdale, AR	100 gal	Grease/baby wipes/Debris	Jet-Vac, Spread Lime out, Hydro Cleaned.	None	Into yard.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that all qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature



Date 02/16/2016

Springdale Water Utilities  
P. O. Box 769  
Springdale, AR 72765-0769



7013 0600 0001 6399 9408

ADEQ  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118



1000



72118

7211835017 R010



U.S. POSTAGE  
\$ R230  
GREENLAND  
FEB 7 21 AM