

# Springdale Water Utilities

Springdale, Arkansas

## System Overflow Report for May 2015

This report submitted to Arkansas Department of Environmental Quality in compliance with Permit Number AR0022063 AFIN: 72-00003

Date	Time	Duration	Address	Est. Vol.	Cause of overflow	Remedial Action	Environmental Impact	Discharge Location
05/06/2015	4:15 pm – 4:50 pm	35 min.	4006 Holt Ave. Springdale, AR	100 gal	Sticks (Vandalism)	Jet-Vac	None	Overflow soaked into ground.
05/08/2015	10:26 am – 10:50 am	24 min.	4618A S. Thompson St. Springdale, AR	1200 gal	Roots, Grease, Debris	Jet-Vac, Disinfected and Deodorized	None	Overflow into ditch.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that all qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Signature

*Heath A. Ward*

Date

6-10-15

**CERTIFIED MAIL™**

Springdale Water Utilities  
P. O. Box-769  
Springdale, AR 72765-0769



7013 0600 0001 6399 9293


ADEQ  
NPDES ENFORCEMENT SECTION  
5301 NORTSHORE DRIVE  
NORTH LITTLE ROCK, AR 72118

72118+5317

NORTHWEST ARKANSAS



1000



72118

U.S. PAID POSTAGE  
SPRINGDALE, AR  
JUN 15 15 15  
AMOUNT  
**\$6.74**  
00016956-03



FOREVER  
USA

Purple Martin

